

CARPET

Must comply with the requirements in the CRI Indoor Air Quality Carpet Testing Program. Not to exceed the following emissions factors measured at the 24 hour test period:

Total Volatile Organic Compounds	0.5 mg/m ² ·hr
Formaldehyde	0.05 mg/m ² ·hr
4-PC (4-Phenylcyclohexene)	0.05 mg/m ² ·hr
Styrene	0.4 mg/m ² ·hr

Product from current production must be retested on a quarterly (3 month) basis to ensure continuing compliance with the test program requirements.

FLOOR COVERING ADHESIVE

Must comply with the requirements of the CRI Indoor Air Quality Adhesive Testing Program. Not to exceed the following emissions factors measured at the 24 hour test period:

Total Volatile Organic Compounds	10.0 mg/m ² ·hr
Formaldehyde	0.05 mg/m ² ·hr
2-ethyl-1-hexanol	3.0 mg/m ² ·hr

Product from current production must be retested on a quarterly (3 month) basis to ensure continuing compliance with the test program requirements.

CARPET CUSHION

Must comply with the requirements of the CRI Indoor Air Quality Carpet Cushion Testing Program. Not to exceed the following emissions factors measured at the 24 hour test period:

Total Volatile Organic Compounds	1.00 mg/m ² ·hr
Formaldehyde	0.05 mg/m ² ·hr
BHT (Butylated Hydroxytoluene)	0.30 mg/m ² ·hr
4-PC (4-Phenylcyclohexene)	0.05 mg/m ² ·hr

Product from current production must be retested on a quarterly (3 month) basis to ensure continuing compliance with the test program requirements.